



पिंपरी चिंचवड महानगरपालिका
अग्निशमन विभाग
Pimpri Chinchwad Municipal Corporation
Fire Department



File No- 1580

OW. No. Fire/DG/MYS/1580 /2025

Date- 01/01/2025

FIRE SAFTY COMPLIANCE CERTIFICATE

Token No – 103324250015087

Token Dt. – 08/11/2024

School Name - PRIYADARSHANI SCHOOL, MOSHI

Address - GAT 195, DEHU-ALANDI ROAD, BORATEWADI, MOSHI, PUNE- 412105
Has applied for Fire Safety Certificate

The Fire Officer has visited the school inspected the Fire Protection System installed at site and as per his technical remarks this NOC is being issued subject to compliance of following conditions.

- 1) The entire fire protection system installed at the site should be maintained in excellent working condition for the any fire emergency.
- 2) The fire extinguishers handling and operational training to be imparted to the teaching/non- teaching/security staff of the school.
- 3) You will carry out testing, maintenance and refilling of all fire extinguishers/fire protection systems from competent person (Govt. Fire Licensed Agency) and necessary Form-'B' Certificate regarding the maintenance and operational condition of the Fire Fighting system to be submitted to the Fire Office as per the Sec.3 (3) of the Fire Act.2016, for every six months in month of January to July, failing of which this NOC shall be treated as cancelled.
- 4) You will keep all the Static Water Tanks full for any fire emergency.
- 5) Fire/Emergency Evacuation Mock Drill should be carried out in the school once in every six months.
- 6) You will keep all passages and corridors free from any obstructions and combustibile material
- 7) "No Smoking Boards" "Emergency Exit" "Assembly Area" and "Emergency Contact Numbers Boards" of Fire, Ambulance, Police, MSEB, shall be always displayed in School to avoid/minimize fire/emergency situation/risk.
- 8) You have to keep fire protection system (fire extinguishers) easily accessible and visible as well as healthy and good working condition.
- 9) You have to install a Safety Net in the Staircase duct and school building construction site in the safety point of view.
- 10) This NOC is issued only from the fire safety point of view. It cannot be treated for any other purposes. However necessary permission from the statutory authorities should be obtained.
- 11) You are not permitted to construct any part of the school building in the school working hours.
- 12) All the rules, regulations declared time to time from the PCMC or Govt. of Maharashtra shall be binding on you and any violation of these shall be viewed seriously.
- 13) This School Operational (Utility) For Buiding A- G +02 Floor and Height 10.97m, with Net Built up Area- 4162.42 Sq. mtrs And Gross Built up Area- 7,500 Sq.mtrs.
- 14) This Fire NOC is valid up to Dt. 01 / 01 /2026 only and renewal of these NOC should be done next year before above mentioned date.

Sub Fire Officer

Pimpri Chinchwad Municipal Corporation
Pimpri -18

To,
The principal
PRIYADARSHANI SCHOOL
GAT 195, DEHU-ALANDI ROAD, BORATEWADI, MOSHI, PUNE- 412105

No.	Particulars	Fees Paid Rs.	Receipt No. And Date
1	Paid For CFC	500/-	R. No. 303324250026691 Dt. 08/11/2024
2	Paid For Certificate	60,100 /-	R. No. 303324250031926 Dt. 01/01/2025

Principal

Priyadarshani School
Aff.No.1130317
Gat No.195, Boratewadi

Manager

Priyadarshani School
Affiliation No. 1130317
Gat No. 195, Dehu - Alandi Road,